

Standard: NFPA 1001 4.3.15(B) (2019 edition)		Skill Sheet: H-5	
Task: While working as a two-person team, the candidates shall demonstrate the ability to connect a pumper to a water supply and advance a forward hose lay while wearing PPE and SCBA.			
Equipment provided by the agency: Appropriate PPE per AHJ, fully-equipped fire pumper.			
Candidate Performance			Fail
Firefighter at Water Supply			
While wearing appropriate PPE, properly dismounts apparatus.			
Gathers and brings all necessary equipment to the hydrant.			
Secures hose to hydrant by wrapping correctly and inspects hydrant for damage (verbalizes) while tightening or loosening appropriate caps.			
Flushes hydrant (per departmental procedures) and signals driver to proceed.			
Completes hydrant connections (per departmental procedures) and awaits engineer's call for water.			
All previous steps in under 2 minutes.			
Fully opens hydrant while standing opposite steamer connection.			
Walks back to apparatus, un-kinking hose and tightening major leaking connections as needed (assists engineer at apparatus if applicable).			
Completes work safely with no interruptions in fluidity of motion.			
Firefighter at Apparatus			
While wearing appropriate PPE per AHJ, dismounts apparatus.			
Properly places hose clamp (if applicable).			
Removes enough hose from hosebed to reach intake and uncouple hose.			
Connects and tightens hose to intake of apparatus.			
Properly removes hose clamp (if applicable).			
Informs Driver/Engineer that connection is complete.			
		Pass	Fail
Performance Outcome: Candidate must pass ALL steps.			
Evaluator Comments			
Location:		Date:	ID Number:
Candidate (Print):		Candidate (Sign):	
Evaluator (Print):		Evaluator (Sign):	